

August 22, 2007

MURPHY SEPTIC SERVICE
GARY MURPHY
2141 SHORT DR.
DEPERE WI 54115

Re: Description: SEWAGE TREATMENT- ULTRAVIOLET DISINFECTION
Manufacturer: MURPHY SEPTIC SERVICE
Product Name: (I) DISINFECT2
Model Number(s): 1
Product File No: 20070086

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. This approval is valid until the end of August 2012.

This approval is contingent upon compliance with the following stipulation(s):

- Installation and maintenance of this product must be in accordance with the manufacturer's printed installation and maintenance instructions.
- System must be maintained at least once every 6 months.
- The wastewater received by this product must have a BOD5 and TSS value of equal to or less than 30 mg/L.
- When this product is installed in a tank, the tank must be approved by the Department of Commerce, Division of Safety and Buildings for use with this product.
- An access opening of sufficient size and location to allow servicing of this product must be provided. This access opening must terminate at or above finish grade.
- The wastewater discharged from this product will have a Fecal Coliform value of equal to or less than 10,000 cfu/100ml.
- The wastewater flow discharge through this product must be equal to or less than 3 gallons per minute.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Michael J. Beckwith, CIPE
Plumbing Product Reviewer
phone: 608-266-6742
fax: 608-267-9566
e-mail: mike.beckwith@wi.gov